

DRAG
LOW

DRAG
LOW



Yearly Event

DRAs in District Heating Networks:
Hydraulic-, Techno- and Economic Simulations


EnerTrans, 14-4-2022

Research questions

- Part 1: What is the potential impact of DRA's on district heating (DH) systems and geothermal wells/reservoirs, and are we able to **set up and validate simulation models** to determine this effect.
- Part 2: Can this effect be quantified by **exporting the resulting network and component design** to link up with the techno-economic phase of the project, comparing non-DRA system results with that of DRA systems.

Final result

- The outcome of this result will consist of models, **guidelines and procedures necessary for implementing DRA parameters** in geothermal well-designs and distribution network modelling, disseminated in the form of detailed reports.



Objectives overview

- Develop a realistic network model (Case study area) ← Activity 4.3
- Assess design implication in geothermal wells/reservoirs ← Activity 4.2
- Develop calibration model based on flow loop setup/design ← Activity 4.1
- Implement DRA's in simulation scenarios ← Activity 4.4
- Perform data analyses and setup export procedure ← Activity 4.5
- Establish guidelines for DRA implementation in heat networks ← Activity 4.6
- Planning:

Result 4	2021				2022				2023				2024			
Activities	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4
4.1 Model calibration																
4.2 Geothermal well design implications																
4.3 Network model development																
4.4 Simulation and DRA implementation																
4.5 Analyses and data export																
4.6 Guidelines for DRA implementation in heat networks																

Progress update

DH Model development: Case study model

- Starting points

Utility (heating)

Utiliteits-gebouw	Aansluit-vermogen [W/m ²]
Kantoren	40
Winkels	70
Scholen	100
Industrie	40

ISSO Publication 7, 2012

- Based on area [m²] and type of building
- Meetings/Events modelled as office space
- Healthcare modelled at 110W/m²
- <https://bagviewer.kadaster.nl/lvbag/bag-viewer/>

Residential (heating)

Bouwjaar	<1946	1946-1981	1982-1998	1998-2010	2010 >
EPC (indicatief)	1,4	1,2	1	0,8	0,6
Aansluit-waardes (kW)					
Vrijstaand	22,0	19,5	16,0	13,0	10,0
Geschakeld	17,5	15,0	12,5	10,0	8,0
Hoek	15,0	12,0	10,0	8,0	7,0
Tussen	13,0	10,5	8,5	7,0	6,0
Appartement rand	13,0	10,5	8,5	7,0	6,0
Appartement tussen	11,0	9,0	7,5	6,0	5,0

Guideline connection values for residential heating, adapted from ISSO Publication 7-2012, figures P. Driessen, and the RVO's energy-saving explorer.

- Termis simulates instantaneous thermal and hydraulic conditions
- Peak load conditions for network dimensioning
- Nominal power [kW] demand also called connection value (P_{cv}):

$$P_{cv} = \Phi_{\text{transmission}} + \Phi_{\text{ventilation}} + \Phi_{\text{heat-up}} + \Phi_{\text{hw}} \quad [\text{W}]$$

Velocity (dimensioning)

DN	Max. Flow Velocity	
	Inside Built Environment	Outside Built Environment
	m/s	m/s
20	0.90	1.30
25	0.90	1.30
32	0.90	1.30
40	1.00	1.50
50	1.20	1.70
65	1.40	1.90
80	1.60	2.20
100	1.80	2.40
125	2.00	2.60
150	2.30	2.80
200	2.30	3.00


Progress update

DH Model development: Case study model

Network layout case study and typical networks

Future capacity increase
- DRA enhancement
- New sources

Various Station points
WOS/WAS



Future demand

Future demand

Progress update

DH Model development: Case study model

- Phase rollout, Consumer database

Phase	Connections		Energy Demand (GJ/yr)		Modelled Capacity (kW)		Actual Capacity (kW)		HE Stations (WOS/WAS)
	Residential	Utility	Residential	Utility	Residential	Utility	Residential	Utility	
1A	540	36	14040,00	34060,32	3780,00	4883,00	2192,40	2832,14	4
1B	347	7	9901,00	1392,05	3271,50	276,20	1897,47	160,20	2
2	474	-	13203,00	-	4227,00	-	2451,66	-	2
3	1018	91	28322,00	42576,26	8023,00	7123,93	4653,34	4131,88	6
4	1176	7	32952,00	268,92	10155,00	53,36	5889,90	30,95	3
5	1356	9	37532,00	4911,41	12031,00	928,80	6977,98	538,70	3
6	1547	12	41637,00	8342,11	10678,00	1655,18	6193,24	960,00	3
6.1	57	1	1482,00	5800,03	399,00	805,56	231,42	467,22	0
6.2	108	-	3024,00	-	648,00	-	375,84	-	1
6.3	189	2	5274,00	286,78	1323,00	56,90	767,34	33,00	0
7	663	16	19129,00	4849,69	6556,00	929,84	3802,48	539,31	2
8	837	75	25236,00	22120,42	8146,50	3647,70	4724,97	2115,66	3
9	1553	8	48476,00	3515,90	16999,50	697,60	9859,71	404,61	5
10	659	6	20167,00	3226,61	7016,50	640,20	4069,57	371,32	2
11	-	16	-	26674,30	-	5180,60	-	3004,75	0
12	-	1	-	86343,02	-	11992,09	-	6955,41	0
99	403	1	10750,00	54310,34	3003,50	4310,34	1742,03	2500,00	2
Total	10524	287	300375	244368	93254	38871	54087	22545	36

Progress update

DH Model development: Case study model


- Phase rollout, Consumer loads



Progress update

DH Model development: Case study model


- Critical velocity areas



Progress update

DH Model development: Case study model


- Critical pressure gradient



Progress update

DH Model development: Case study model

- Primary vs. Secondary



Pipe Types	Total
N020	637,07
N025	2728,05
N032	6614,58
N040	3628,30
N050	7346,77
N065	8440,32
N080	5424,64
N100	6103,96
N125	5702,32
N150	2765,98
N200	2702,10
N250	1337,72
N300	928,35
N350	768,13
N400	1364,94
N450	373,85
N500	0,00
N600	6,09
	56873,17


Estimated pipe lengths and diameters (30% Primary)

- Higher proportional CAPEX saving in primary network
- Reducing pre-investment required for future developments
- **18-20%** CAPEX saving reducing entire network with 1 size

Progress update

DH Model development: Case study model

- Source planning: base load vs. peak load



Next steps

Flow loop model: Calibration module (Q1-Q2, 2022)

Result 4	2021				2022				2023				2024			
Activities	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4
4.1 Model calibration																
4.2 Geothermal well design implications																
4.3 Network model development																
4.4 Simulation and DRA implementation																
4.5 Analyses and data export																
4.6 Guidelines for DRA implementation in heat networks																



- Model to represent the experimental **flow loop** setup
- Process and system boundary conditions considered during DRA performance testing (T, Q, P)
- Input Result 2: Measurements at **various test conditions and DRA concentrations**
- DRA parameters as pressure correction factors or modified object properties (i.e. roughness in pipes)
- To implement in case study network in activity 4.4

Calibration



Targeted at a path with comparison between two node objects

Comparison between simulation- and measured results

Output: correction factor that is stored as an attribute for all pipes.

Correction factor calculation:

$$\phi = \frac{\Delta X_{Measured}}{\Delta X_{Simulated}}$$



Next steps



Calibration parameters (Q3-Q4, 2022)

- Pipe roughness (25-30%)
- Fluid parameters (>50%)

Dynamic viscosity

$$\mu = \exp(a_v + \beta T)$$



- Development in progress



Next steps

Simulation and DRA implementation (Q3-Q4, 2022)

- Create scenarios to simulate
→ Non-DRA vs. DRA system
- Test calibration module and verify DRA parameter implementation
- Execute conventional system calculation
- Execute DRA system calculation
- Increase flexibility in dataset if necessary (export phase)
- (Bonus): Set up DRA model template for future models/systems




GUI Calibration module dashboard

Next steps


Geothermal well design implications (Q1-Q2, 2022)

- Effects of DRA injection on geothermal well design
- Simulate effects of DRA mixture on dynamic well and reservoir pressure loss
 - Operational limits (Injection pressure, ESP design, erosional velocity, etc.)
 - Design guideline - parameters required to modify well designs – long term impact, cold water breakthrough
 - **Integration** with DH networks, input to DH modelling as boundary conditions (flowrate etc.)



Geothermal results as input boundary conditions (P, Q)

DH Network




Next steps

Analyses and data exports (Q1, 2023)

- Export format and procedure
- BuCa requirements (Result 6)
- Pipe data export per scenario/simulation
- Non-DRA vs. DRA system results
- Various object exports (plants, stations, valves, etc.)
- Master file **link** with techno-economic model (Result 6)
- Online available BuCa assessment tool for public use

Sim12: Primary line connected to StFranciscus in the South.

Plant Control	PL_110MA:PL_110MA	PL_WP_H	Plant Results	PL_110MA:PL_110MA	PL_WP_HTO
Power Control [kW]			Power [kW]		73584,63
Flow Control [kg/s]			Flow [kg/s]		520,18
Inlet Temperature Control [°C]	75,00	75,00	Volumetric Flow [m³/h]		1886,43
Static Supply Pressure [bar]			Temperature, Supply, Plant [°C]		75,00
Static Return Pressure [bar]	2,00	2,00	Temperature, Return, Plant [°C]		41,26
Static Pressure [bar]			Temperature, Difference [°C]		33,74
Percent of Pressure Difference			Pressure, Supply [bar]		7,49
Control Node	PL_110MA:PL_110MA	NO_1369	Pressure, Return [bar]		2,00
Node Supply Pressure Control [bar]			Pressure, Difference [bar]		5,49
Node Return Pressure Control [bar]			Power, Pump [kW]		287,56
Node Pressure Change Control [bar]	-1,50	-1,50	Energy Cost, Production [CU/s]		0,00
			Actual speed [rps]		NaN
			Energy Cost, Pump [CU/s]		0,00
			Production Units		
			Actual Control Node	PL_110MA:PL_110MA	NO_1369



PHASE	DSIM_1	DSIM_2	DSIM_3	DSIM_4	DSIM_5	DSIM_6	DSIM_7	DSIM_8	DSIM_9	DSIM_10
1	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00
2	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00
3	€ 0,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00
4	€ 0,00	€ 0,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00
5	€ 0,00	€ 0,00	€ 0,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00
6	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00
7	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 1 000,00	€ 1 000,00	€ 1 000,00	€ 1 000,00
8	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 1 000,00	€ 1 000,00	€ 1 000,00
9	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 1 000,00	€ 1 000,00
10	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 1 000,00	€ 1 000,00
11	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 1 000,00	€ 1 000,00
12	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 0,00	€ 1 000,00
Total	€ 2 000,00	€ 3 000,00	€ 4 000,00	€ 5 000,00	€ 6 000,00	€ 6 000,00	€ 7 000,00	€ 8 000,00	€ 11 000,00	€ 12 000,00

Looking forward

Guidelines for DRA implementation in DH and geothermal design and modelling (Q3, 2023)

- Best “tools” for the job (software, methods, etc.)
- DRA parameter development
- Most effected areas using DRA’s (“low hanging fruit”)
- Most significant effects on CAPEX and OPEX
- Sensitivity analyses
- General knowledge share





Thank you for listening